
Certificate of Analysis

Chemical Name:	ATMP
Batch No.:	2020031001
Manufacture Date:	2020-03-10
Expiry Date:	2021-03-09
Quantity:	20 MT

The above chemical was tested and the following results have been obtained:

Test Item	Standard	Result
Appearance	Colorless to pale yellow transparent liquid	Pale yellow transparent liquid
Active content %	50 min	50.59
Phosphorous acid(as PO_3^{3-})%	3.5 max	1.97
Phosphoric acid (as PO_4^{3-})%	0.8 max	0.66
pH (1% water solution)	2.0 max	1.68
Density (20°C)g/cm ³	1.31-1.35	1.331
Fe ion ppm	10.0 max	6.35
Color (APHA)	40.0 max	30.00
Chloride (as Cl-)%	1.0 max	0.53
Conclusions		Qualified